

C € 0085



CERT


# EU type examination certificate

## EU-Baumusterprüfbescheinigung

**CE-0085BU0133**  
Product Identification No.  
Produkt-Identnummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	CAVAGNA GROUP S.P.A. - divisione RECA - Via Matteotti, 5, I-25012 Viadana di Calvisano (BS)
<b>Distributor</b> <i>Vertreiber</i>	CAVAGNA GROUP S.P.A. - divisione RECA - Via Matteotti, 5, I-25012 Viadana di Calvisano (BS)
<b>Product Category</b> <i>Produktart</i>	gas fittings: Pressure regulator for LPG (4302)
<b>Product Description</b> <i>Produktbezeichnung</i>	Pressure regulator for LPG with non adjustable outlet pressure
<b>Model</b> <i>Modell</i>	694, 694 D, 694 M
<b>Countries of Destination</b> <i>Bestimmungsländer</i>	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
<b>Test Reports</b> <i>Prüfberichte</i>	type testing: 544/3017/1453 from 07.02.2018 (FGL)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 16129 (01.08.2013)

**Validity / File no.** 21.04.2018 until 03.04.2028 / 17-0533-GEA  
**Gültigkeit / AZ**

03.04.2018 Rie A-1/2   
Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-01

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

<b>Gas Category</b> <i>Gasart</i>	<b>Remarks</b> <i>Bemerkungen</i>
LPG	

<b>Type</b> <i>Typ</i>	<b>Technical Data</b> <i>Technische Daten</i>	<b>Remarks</b> <i>Bemerkungen</i>
694	outlet pressure: 29 (B); 37, 50 (P); 29, 30, 50 (LPG) mbar inlet pressure range: 0,3...7,5 (B); 1,0...16,0 (P); 0,3...16,0 (LPG) bar nominal pressure rating: PN 16 nominal flow rate: 1,3 (B); 1,5/2,0 (P); 1,5 (LPG) kg/h	
694D; 694M	outlet pressure: 30 (LPG) mbar inlet pressure range: 0,3...16,0 (LPG) bar nominal pressure rating: PN 16 nominal flow rate: 0,8 kg/h	

<b>Type Variation</b> <i>Ausführungsvariante</i>	<b>Explanations</b> <i>Erläuterungen</i>
694	single stage regulator
694D	single stage regulator according to DIN EN 16129, annex D
694M	single stage regulator according to DIN EN 16129, annex M

#### **Hints of Utilization /Remarks**

##### **Verwendungshinweise / Bemerkungen**

optional: manometer, excess flow device with an automatic re-setting "EFV", overpressure (max. 150 mbar) relief valve of limited flow rate "PRV"

ambient temperature range: 0...+50 °C (B); -20...+50 °C (P, LPG)

connection: at the input side G.1, G.2, G.4, G.5, G.6, G.7, G.8, G.9, G.10, G.12, G.25, at the outlet side H.4, H.50, H.51, H.53; each according to DIN EN 16129

PRV-response pressure: max. 150 mbar

In Macedonia the CE-marking will be accepted as conformaty approval if the Gas Appliance Regulation EU/2016/426 is transferred into national law by Macedonia.